



## EC DECLARATION OF CONFORMITY

Fire & Gas Detection Technologies Inc. declares under our sole responsibility that our equipment or protective system conform to the relevant safety and health related requirements of the appropriate EU directive.

|                                       |   |
|---------------------------------------|---|
| <b>Equipment or protective system</b> | FlameSpec IR3-HD Flame Detector   |
| Model No.                             | FLS-IR3-H2-ASX1   |
| Serial No.                            |   |
| <b>ATEX Directive</b>                 | <b>2014/34/EU</b>   |
| Approval Body                         | ICQC LTD 63-19, Skolas Street, Jurmala, LV-2016 Latvia  |
| Notified body No.                     | 2549  |
| EC Certificate Number(s):             | ICQC19ATEX 423X   |
| Reference Standards                   | EN 60079-0:2012/A11 :2013,<br>EN 0079-1:2014,<br>EN 60079-7 :2015,<br>EN 60079-31 :2014   |
| Markings                              |  II2G Ex db IIC T5 Gb<br>II2D Ex tb IIIC T95°C Db<br>-55°C<Ta<75°C<br><br> II2G Ex db IIC T4 Gb<br>II2D Ex tb IIIC T105°C Db<br>-55°C<Ta<85°C |
| <b>EMC Directive</b>                  | <b>2014/30/EU</b>   |
| Reference Standards                   | EN50130-4 :2011<br>EN6100-6-4 :2007/A1 :2011  |

Name : Shaul Serero

Date : **18.6.2020**

Signature : 